



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

**NOTICE OF ACCEPTANCE (NOA)**

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**Premium Spray Products, Inc.**  
**1255 Kennestone Circle, Suite 200**  
**Marietta, GA 30066**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Premiseal™ Spray Polyurethane Roofing Foam over Recover Decks**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city and state of manufacturing facility, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 7.

The submitted documentation was reviewed by Juan E. Collao, R.A.



NOA No.: 14-0512.02  
Expiration Date: 12/24/19  
Approval Date: 12/24/14  
Page 1 of 7

**ROOFING COMPONENT APPROVAL**

**Category:** Roofing  
**Sub-Category:** Spray Applied Polyurethane Roof System  
**Materials:** Polyurethane  
**Deck Type:** Recover  
**Maximum Design Pressure:** -435 psf

**TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:**

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Premiseal™ 280	2.8 lb/ft <sup>3</sup> density	TAS 110	Two-component spray applied polyurethane foam intended for roofing applications.

**EVIDENCE SUBMITTED:**

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Atlantic & Caribbean Roof Consulting, LLC	TAS 114 D	ACRC 14-013	04/29/14
	TAS 114 D	ACRC 14-014	04/29/14
	TAS 114 D	ACRC 14-015	04/29/14
FM Approvals	4470	0003047138	08/28/13
	ASTM E108		
	TAS 114		
PRI Construction Materials Technologies	TAS 110	PSP-002-02-03	12/11/14
Underwriters Laboratories	Fire Classification	TGFU.R26705	01/09/14



## APPROVED ASSEMBLIES:

<b>Deck Type 7:</b>	Recover
<b>Deck Description:</b>	Min. 2500 psi structural concrete deck; with a gravel surfaced BUR system fully adhered to the concrete deck.
<b>System Type A(1)</b>	Sprayed polyurethane foam covered with a Miami-Dade County approved roof coating.

### All General and System Limitations apply.

**Surface Preparation:** For recover applications, existing roof shall be in compliance with applicable Building Code and Roofing Application Standard RAS 109.

Surfaces shall be primed, if required, in accordance to Premium Spray Products, Inc.'s and coating manufacturers' recommendations, and shall be free of loose dirt, grease, oil or other contaminants prior to priming or foam application. Remove loose dirt or debris by use of compressed air, vacuum or brooming. No washing shall be permitted. Oil, grease, release agents or other contaminants shall be removed with proper cleaning solutions.

Primers shall be applied if required, in accordance with the manufacturer's instructions. All primers must be thoroughly dry and cured prior to foam application.

**Polyurethane Foam Application:** The polyurethane foam shall be applied uniformly over the entire surface at the specified thickness, in no case shall it be less than 1", in compliance with the requirements set forth Roofing Application Standard RAS 109. The sprayed polyurethane foam shall be feathered at the edges to produce a smooth transition.

**Protective Coating Application:** Apply a Miami-Dade County approved roof coating with a current NOA that is compatible with this system and is applied in accordance with the guidelines listed in the product's NOA.

The polyurethane foam surface shall be free of moisture, dust, debris, oils, tars, grease or other materials that will impair adhesion of the protective coverings. Any damage or defects to the polyurethane foam surface shall be repaired prior to the coating application. The base coat shall be applied the same day as the foam when possible. If more than 72 hours elapse prior to the application of the base coat, the polyurethane foam shall be inspected for UV degradation.

**Maximum Design Pressure:** -392.5 psf. (See General Limitation # 6)



**Deck Type 7:** Recover

**Deck Description:** Min. 2500 psi structural concrete deck; with an existing smooth surfaced BUR system fully adhered to the concrete deck.

**System Type A(2)** Sprayed polyurethane foam covered with a Miami-Dade County approved roof coating.

**All General and System Limitations apply.**

**Surface Preparation:** For recover applications, existing roof shall be in compliance with applicable Building Code and Roofing Application Standard RAS 109.

Surfaces shall be primed, if required, in accordance to Premium Spray Products, Inc.'s and coating manufacturers' recommendations, and shall be free of loose dirt, grease, oil or other contaminants prior to priming or foam application. Remove loose dirt or debris by use of compressed air, vacuum or brooming. No washing shall be permitted. Oil, grease, release agents or other contaminants shall be removed with proper cleaning solutions.

Primers shall be applied if required, in accordance with the manufacturer's instructions. All primers must be thoroughly dry and cured prior to foam application.

**Polyurethane Foam Application:** The polyurethane foam shall be applied uniformly over the entire surface at the specified thickness, in no case shall it be less than 1", in compliance with the requirements set forth Roofing Application Standard RAS 109. The sprayed polyurethane foam shall be feathered at the edges to produce a smooth transition.

**Protective Coating Application:** Apply a Miami-Dade County approved roof coating with a current NOA that is compatible with this system and is applied in accordance with the guidelines listed in the product's NOA.

The polyurethane foam surface shall be free of moisture, dust, debris, oils, tars, grease or other materials that will impair adhesion of the protective coverings. Any damage or defects to the polyurethane foam surface shall be repaired prior to the coating application. The base coat shall be applied the same day as the foam when possible. If more than 72 hours elapse prior to the application of the base coat, the polyurethane foam shall be inspected for UV degradation.

**Maximum Design Pressure:** -435 psf. (See General Limitation # 6)



**Deck Type 7:** Recover

**Deck Description:** Min. 2500 psi structural concrete deck; with an existing granulated surfaced BUR system fully adhered to the concrete deck.

**System Type A(2)** Sprayed polyurethane foam covered with a Miami-Dade County approved roof coating.

**All General and System Limitations apply.**

**Surface Preparation:** For recover applications, existing roof shall be in compliance with applicable Building Code and Roofing Application Standard RAS 109.

Surfaces shall be primed, if required, in accordance to Premium Spray Products, Inc.'s and coating manufacturers' recommendations, and shall be free of loose dirt, grease, oil or other contaminants prior to priming or foam application. Remove loose dirt or debris by use of compressed air, vacuum or brooming. No washing shall be permitted. Oil, grease, release agents or other contaminants shall be removed with proper cleaning solutions.

Primers shall be applied if required, in accordance with the manufacturer's instructions. All primers must be thoroughly dry and cured prior to foam application.

**Polyurethane Foam Application:** The polyurethane foam shall be applied uniformly over the entire surface at the specified thickness, in no case shall it be less than 1", in compliance with the requirements set forth Roofing Application Standard RAS 109. The sprayed polyurethane foam shall be feathered at the edges to produce a smooth transition.


**Protective Coating Application:** Apply a Miami-Dade County approved roof coating with a current NOA that is compatible with this system and is applied in accordance with the guidelines listed in the product's NOA.

The polyurethane foam surface shall be free of moisture, dust, debris, oils, tars, grease or other materials that will impair adhesion of the protective coverings. Any damage or defects to the polyurethane foam surface shall be repaired prior to the coating application. The base coat shall be applied the same day as the foam when possible. If more than 72 hours elapse prior to the application of the base coat, the polyurethane foam shall be inspected for UV degradation.

**Maximum Design Pressure:** -312.5 psf. (See General Limitation # 6)



**TABLE 1**  
**AMBIENT HUMIDITY APPLICATION LIMITS**  
**SPRAYED POLYURETHANE FOAM**



## **RECOVER SYSTEM LIMITATIONS:**

1. The moisture content of an existing roof system shall be in compliance with applicable Building Code.
2. Existing low slope roof systems shall be tested for uplift resistance in compliance with Testing Application Standard TAS 124 to the calculated design pressures of the field, perimeter and corner areas, determined in compliance with applicable Building Code.
3. Lightning rods shall be masked prior to foaming. Lightning rod cables shall not be embedded in the polyurethane foam and should be removed prior to foaming. Electrical and mechanical conduits should be relocated or raised above the finished roof surface.

## **GENERAL LIMITATIONS:**

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Spray polyurethane foam shall not be sprayed when ambient temperature is within 5 degrees of the dew point. Ambient humidity applications limits shall be as listed in Table 1 herein. Contractor shall monitor and record environmental conditions in the Job Log in compliance with RAS 109. Job Log shall be maintained at the job site and accessible to the Building Official.
3. Flashings and waterproof coverings for expansion joints shall be of compatible materials and in accordance with Premium Spray Products, Inc.'s published literature.
4. Miscellaneous materials such as adhesives, elastomeric caulking compounds, metal, vents and drains shall be a composite part of the roof system and shall be compatible with the foam and coating.
5. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
6. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners).
7. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**

